



# Desalination Engineering Feasibility Study-Update

## Santa Clara Valley Water District

Recycled Water Committee

May 27, 2026



# Agenda

- Study Overview and Approach
- Selection of Alternatives
- Production, Brine Discharge and Conveyance
- Project Alternatives Costs - CAPEX/OPEX
- Desal and DPR Costs
- Next Steps

# Study Overview & Approach

# Fatal Flaw Analysis (FFA)

## Fatal Flaw


- May face permitting challenges when evaluated against relevant regulatory framework, such as the California Ocean Plan, Bay Plan, or SF Basin Plan.
- Alternative is unlikely to meet capacity needs.

## Feasible as defined by CEQA and the CA Ocean Plan

- Feasible shall mean capable of being accomplished within a reasonable time, considering economic, environmental, social, and technological factors.

# Fatal Flaw Analysis Components

- **Intakes**
  - Subsurface
  - Open intake
    - Type, location, and screen options
- **Facility Siting**
  - Several sites analyzed
- **Brine Management**
  - Comingling brine with treated wastewater
  - New Deep outfall with diffusers
  - Horizontal levees
  - Cargill use



# Regulatory Framework



## California Water Code section 13142.5(b)

Excerpt: “... coastal industrial installations using seawater, the best available site, design, technology and mitigation measures feasible shall be used to minimize the intake and mortality of all forms of marine life.”

## California Ocean Plan

CA Ocean Plan provides regulatory guidance for the application of CWC section 13142.5(b) to seawater desalination plants utilizing “ocean water”.

The San Francisco Bay is not subject to the CA Ocean Plan’s seawater desalination regulations; however, **the fatal flaw’s feasibility analysis utilizes the CA Ocean Plan as guidance** because it represents the most conservative regulatory scenario.

# Selection of Alternatives

# FFA-Open Intake Location


## Open Intake Locations

### Key Considerations:

- Sufficient depth
- Available Water
- Proximity to Treatment Sites
- Proximity to Inland locations for freshwater dilution

### Passing Fatal Flaw Analysis

- ✓ **D** = Guadalupe Slough
- ✓ **E** = Coyote Creek
- ✓ **F** = Deep Bay
- ✓ **G** = Interconnecting Channel





# Site Alternatives



Site No. 11, Palo Alto



Site No. 6 and 7, Sunnyvale




Site No. 12. San Jose

# Brine Management

## Options Evaluated

- Comingling with Treated Wastewater Effluent from Existing WWTP
- New Deep Bay Outfall with Brine Diffuser




# Feasible Alternatives



# Ranking Alternatives

Table ES-1 Shortlisted Options with Scoring and Ranking Results

Options	Weighted Sum Method		TOPSIS	
	Aggregated Score	Option Ranking	Aggregated Score	Option Ranking
<b>Intake</b>				
<b>Interconnecting Channel</b>	<b>3.6</b>	<b>1</b>	<b>66%</b>	<b>1</b>
Guadalupe Slough	3.2	4	37%	4
Coyote Creek	3.3	2	39%	3
Deep Bay	3.2	4	40%	2
<b>Desalination Facility Site</b>				
6+7 (Sunnyvale)	3.9	2	41%	2
11 (Palo Alto)	3.9	2	40%	3
12 (San Jose)	4.2	1	66%	1
<b>Brine Management</b>				
Deep Bay Discharge	2.9	2	45%	2
<b>Commingling with Wastewater</b>				
	3.6	1	55%	1




valleywater.org

# Production, Brine Discharge and Conveyance

# Typical Desalination Treatment Process

15




valleywater.org

# Product Water and Brine Produced

**Table A. Product Water, Pipeline Diameter and Brine Produced**

Source Water (MGD)	Product Water (MGD) @ 42% Recovery	Product Water Pipeline Diameter (inches)	Brine Discharge (MGD)
24	10	30	14
47	20	42	28
95	40	60	55

# Conveyance and Distribution




valleywater.org

# Project Alternatives Cost

# Range of Capital Expenditures (CAPEX)


18 Distinct  
Combinations with  
2 Conveyance Options

Production Capacity  
10, 25 and 40 MGD



# Desal & DPR Costs

# Top Alternative-24 MGD



valleywater.org

# Unit Cost & CAPEX- 24 MGD




Figure 4 Comparison of CAPEX Unit Cost for Desalination and DPR




Figure 5 CAPEX by Component for Desalination and DPR

# OPEX by Element- 24 MGD




Figure 6 Annual OPEX by Element for Desalination and DPR (Note: consumables are considered negligible in the planning-level estimates for both programs)





Figure 7 Annual OPEX Comparison by Element

# Desal vs. DPR: Total Unit Cost (CAPEX + OPEX) 24 MGD




Figure 1 Comparison of Total CAPEX, Unit CAPEX, and Unit OPEX for 24 MGD Desalination and DPR

# Desalination EFS - Staff Recommended Next Steps 25

Amend existing agreement with B&V to extend contract by one year and increase budget to complete additional work, including:

- Hydrodynamic and salinity modeling (San Jose/Deep Bay)
- Investigate water quality and bathymetry
- Investigate Interconnecting Channel near Sunnyvale Pond A4
- Additional regulatory and resource agency coordination



# Valley Water

Clean Water • Healthy Environment • Flood Protection