

CAPITAL PROGRAM SERVICES
5750 ALMADEN EXPRESSWAY
SAN JOSE, CA 95118-3686
TELEPHONE (408) 630-3088
FACSIMILE (408) 979-5631
www.valleywater.org
scvwdplanroom@valleywater.org

*Notification of this Addendum is transmitted via email to all current plan holders.
This Addendum is posted on the District website at
www.valleywater.org/Construction*

June 1, 2018

ADDENDUM NO. 2
TO CONTRACT DOCUMENTS FOR THE
STEVENS CREEK BANK AND ACCESS/TRAIL ROAD REPAIR
DOWNSTREAM OF EL CAMINO REAL (SR 82) PROJECT
Project No. 62062003 Contract No. C0638

Notice is hereby given to Prospective Bidders that the Contract Documents are modified as hereinafter set forth.

SPECIFICATIONS AND CONTRACT DOCUMENTS

SPECIAL PROVISIONS

SECTION 18. PERMITS AND REGULATIONS

Article 18.06. Traffic Control

REPLACE Paragraph L. in its entirety with:

- "L. Attention is directed to Section 7-1.03, "Public Convenience," Section 7-1.04, "Public Safety," and Section 12, "Temporary Traffic Control," of the State Standard Specifications and Article 8.01, "Public Safety," of these Specifications. Nothing in these Specifications shall be construed as relieving the Contractor from his/her responsibility as provided in said Section 7-1.04, "Public Safety," of the State Standard Specifications."

ADDENDUM NO. 2
Santa Clara Valley Water District
STEVENS CREEK BANK AND ACCESS/TRAIL ROAD REPAIR D/S OF SR 82

TECHNICAL PROVISIONS

SECTION 23. PREPARATORY WORK

Article 23.01.03. Placement

REPLACE Paragraph D. in its entirety with:

- "D. Concrete removal shall conform to this section of these Specifications and the provisions of Section 15-3, Concrete Removal, of the 2010 State Standard Specifications, except as modified herein."

Article 23.05.04. Submittals

REPLACE Paragraph A. and items 1., 2., and 3., in their entirety with:

- "A. Submit a Certificate of Compliance under Section 6-1.07, "Certificates of Compliance" of the 2006 State Standard Specifications for:
1. Mirafi TM 13C or approved equal
 2. Anchor
 3. Sample of Mirafi TM13C and Anchors"

Article 23.06.01.02. Materials

REPLACE Paragraph A. in its entirety with:

- "A. All fencing shall be in accordance with Section 80 "Fences" of the State Standard Specifications."

Article 23.06.02.02. Materials

REPLACE Paragraphs C. and G. in their entirety with:

- "C. Fence posts shall be 6-inch by 6-inch and 98 3/8-inches long with 48-inches set in concrete.
- G. PVC sleeve shall be DR/SDR 26 with 18-inch diameter and 48-inch length."

Article 23.06.02.03. Submittals

REPLACE Paragraph C. in its entirety with:

- "C. PVC sleeve, wire mesh"

ADDENDUM NO. 2

Santa Clara Valley Water District

STEVENS CREEK BANK AND ACCESS/TRAIL ROAD REPAIR D/S OF SR 82

Article 23.06.03.05. Placement

REPLACE Article 23.06.03.05.A. through C. in their entirety with:

- "A. PVC sleeve and concrete posts within the sleeve shall be set true to line and grade.
- B. Set PVC sleeve posts in 18-inch diameter extending 48-inches to receive concrete for fence post.
- C. The PVC sleeve to receive concrete for fence post shall be carefully placed during construction of geogrid. Drilling or cutting activities should not impact the material strength of the geogrid, erosion control geotextile fabric and pavement filter fabric. The surrounding geogrid and geotextile fabric should not pop out."

ADD New Article title as follows:

"Article 23.06.03. Not Used"

Article 23.06.04.02. Materials

REPLACE Paragraph B. in its entirety with:

- "B. The thickness of the asphalt concrete shall be 5-inch minimum AC with prime coat plus 6-inch Class 3, aggregate base (AB)."

SECTION 24. EARTHWORK

Article 24.01.02.01. Scope of Work

REPLACE Paragraph F. in its entirety with:

- "F. Contractor shall install rootwad along the rock riprap at downstream end. Rootwad shall be wedged between the bottom and top layers of rock. Rootwad shall be tethered with 5/8-inch steel cable and anchored to native material at the bottom of the rock trench with two Type B1 anchors by Propex operating company or Tensar NAG Earth Anchors EA680 or Approved Equal and 5/8-inch cables. Anchors shall be installed by percussion anchor installation method. A minimum of two cable clamps shall be used at cable to cable connections per 1998 California Salmonid Stream Habitat Restoration Manual, Figure VII-4, Page VII-12."

Article 24.01.02.03. Placement

DELETE Paragraph D. in its entirety

Article 24.01.02.06. Measurement

DELETE Paragraph G. in its entirety

ADDENDUM NO. 2

Santa Clara Valley Water District

STEVENS CREEK BANK AND ACCESS/TRAIL ROAD REPAIR D/S OF SR 82

Article 24.01.03.02. Materials and Placement

DELETE Paragraph H. in its entirety

SECTION 25. ROCK RIPRAP

Article 25.02.02. Materials and Execution

REPLACE Paragraph A. in its entirety with:

- "A. The geotextile fabric as shown on the Plans shall be between the soil and rock lining protection and be a nonwoven stabilization fabric equivalent to Mirafi 1100NC or approved equal meeting Section 96-1.02I, Class 10 of the State Standard Specifications."

BID FORM NO. 1 (REV. 1) FEDERAL REQUIREMENTS Proposal and Bid Items

SECTION B SUPPLEMENTAL BID ITEMS

NOTE:

"The right most TOTAL for Item 1 shall be equal to the UNIT PRICE for Item 1.

The right most TOTAL for Item 2 shall be equal to the UNIT PRICE for Item 2."

GENERAL QUESTIONS & RESPONSES


Question 1	What is the pay item for reusing existing rock?
Response 1	The pay item for reusing existing rock is Bid Item #11.
Question 2	Is the quantity of stockpile material included in Bid Item 9?
Response 2	Yes, the stockpile quantity is included in Bid Item #9. The stockpile quantity is not included in Bid Item #10.
Question 3	Regarding Builders Risk coverage under 14.16.01.C, please confirm if it will be acceptable for the coverage period for Builders Risk policy to end at Milestone #1?
Response 3	Yes. Builders Risk (course of construction) insurance coverage requirement as specified in Article 14.16.01.C. will end at the completion of Milestone #1 and after acceptance of the Project by the Board of Directors.

THIS ADDENDUM NO. 2, WHICH CONTAINS 5 PAGES, IS ATTACHED TO AND IS PART OF THE SPECIFICATIONS AND CONTRACT DOCUMENTS FOR THIS PROJECT.



Venkatesan Narasimhalu, P.E., P.L.S.
Capital Engineering Manager
Design and Construction Unit

Date: 5/31/18



Ngoc Nguyen, P.E.
Deputy Operating Officer
Watersheds Design and Construction Division

Date: 6/01/18

THIS PAGE INTENTIONALLY LEFT BLANK