

Pacheco Pumping Plant Electrical Current Limiting Fuse & HVOS Upgrades (Project Number 91214010)

Public Hearing - February 9,
2021




Board Actions – February 9, 2021

- ▶ Conduct Public Hearing on Engineer's Report;
- ▶ Close Public Hearing;
- ▶ Approve Engineer's Report;
- ▶ Approve Project.

Project Objectives

- ▶ Pacheco Electrical Current Limiting Fuse & HVOs Upgrades: Reduce the risk of an unplanned event that could result in an occupational injury, asset damage, or plant shutdown.

Projects' Location



Project Description

PPP Electrical Current Limiting Fuse & HVOS Upgrades

- ▶ Install Current Limiting Fuses on the 480V station service transformers
- ▶ Replace the existing Hydraulic Valve Operating System (HVOS) Motor Control Center (MCC) and control.



Project Right of Way

- ▶ The project is within the limits of United States Bureau of Reclamation (BOR) facility.
- ▶ Coordination with BOR before construction will be required.

Project Cost / Zone Funding

- ▶ Pacheco PP Electrical Current Limiting Fuse & HVOS Upgrades
 - ▶ Estimated total cost: \$550,000 (2020 dollars)
 - ▶ Zone of Benefit:
 - W-2 (82.3%)
 - W-5 (8.0%)
 - W-7 (9.7%)

Project's Next Steps

- ▶ Advertise for Bids for Construction – June 2021
- ▶ Award Construction Contract –August 2021
- ▶ Initiate Construction – September 2021

Questions



THIS PAGE INTENTIONALLY LEFT BLANK